

**BI**  **ICT**

**IT'16**  
ŽABLJAK

**XXI**

*međunarodni naučno - stručni skup*

**INFORMACIONE  
TEHNOLOGIJE**

*SADAŠNJOST I BUDUĆNOST*

Urednik  
Božo Krstajić

**IT'16**

**INFORMACIONE  
TEHNOLOGIJE**

**- SADAŠNJOST I BUDUĆNOST -**

**Urednik**  
*Božo Krstajić*

*Zbornik radova sa XXI međunarodnog naučno - stručnog skupa  
INFORMACIONE TEHNOLOGIJE - sadašnjost i budućnost  
održanog na Žabljaku od 29. februara do 05. marta 2016. godine*

Zbornik radova  
INFORMACIONE TEHNOLOGIJE - sadašnjost i budućnost 2016

*Glavni urednik*  
Prof. dr Božo Krstajić

*Izdavač*  
Univerzitet Crne Gore  
Elektrotehnički fakultet  
Džordža Vašingtona bb., Podgorica  
[www.etf.ucg.ac.me](http://www.etf.ucg.ac.me)

*Tehnička obrada*  
Aleksandra Radulović  
Centar informacionog sistema  
Univerziteta Crne Gore

*Tiraž*  
150

Podgorica 2016.

*Sva prava zadržava izdavač i autori*

## **Organizator**

Elektrotehnički fakultet, Univerzitet Crne Gore

## **Suorganizatori:**

BIO-ICT Centar izvrsnosti

## **Skup su podržali:**

Ministarstvo za informaciono društvo i telekomunikacije

Ministarstvo nauke

## **Programski odbor**

Dr Novak Jauković, Elektrotehnički fakultet, Podgorica, MNE  
Dr Ljubiša Stanković, Elektrotehnički fakultet, Podgorica, MNE  
Dr Zdravko Uskoković, Elektrotehnički fakultet, Podgorica, MNE  
Dr Vujica Lazović, Ekonomski fakultet, Podgorica, MNE  
Dr Branko Kovačević, Elektrotehnički fakultet, Beograd, SRB  
Dr Milorad Božić, Elektrotehnički fakultet, Banja Luka, BIH  
Dr Miroslav Bojović, Elektrotehnički fakultet, Beograd, SRB  
Dr Zoran Jovanović, Elektrotehnički fakultet, Beograd, SRB  
Dr Milica Pejanović-Đurišić, Elektrotehnički fakultet, Podgorica, MNE  
Dr Despina Anastasiadou, Research & Development Innovation Academy, Solun, GRC  
Dr Dejan Popović, Elektrotehnički fakultet, Beograd, SRB  
Dr Gabriel Neagu, National Institute for Research & Development in Informatics, Bucharest, ROU  
Dr Božo Krstajić, Elektrotehnički fakultet, Podgorica, MNE  
Dr Tomo Popović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Milovan Radulović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Le Xie, Texas A&M University, College Station, TX, USA  
Dr Sašo Gelev, Elektrotehnički fakultet, Radoviš, MKD  
Dr Budimir Lutovac, Elektrotehnički fakultet, Podgorica, MNE  
Dr Igor Radusinović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Alex Sprintson, Texas A&M University, College Station, TX, USA  
Dr Nikša Tadić, Elektrotehnički fakultet, Podgorica, MNE  
Dr Miloš Daković, Elektrotehnički fakultet, Podgorica, MNE  
Dr Milutin Radonjić, Elektrotehnički fakultet, Podgorica, MNE  
Dr Ana Jovanović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Vesna Rubežić, Elektrotehnički fakultet, Podgorica, MNE  
Dr Ramo Šendelj, Fakultet za Informacione Tehnologije, Podgorica, MNE  
Dr Stevan Šćepanović, Prirodno-matematički fakultet, Podgorica, MNE

## **Organizacioni odbor**

Dr Božo Krstajić, Elektrotehnički fakultet, Podgorica, MNE  
Dr Milovan Radulović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Zoran Veljović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Ana Jovanović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Saša Mujović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Tomo Popović, Elektrotehnički fakultet, Podgorica, MNE  
Dr Žarko Zečević, Elektrotehnički fakultet, Podgorica, MNE  
Vladan Tabaš, dipl.ing., Čikom, Podgorica, MNE

## **Sekretarijat**

Aleksandra Radulović, CIS Univerzitet Crne Gore, MNE

Radiša Stefanović, Aleksa Srdanov POBOLJŠANJE EFIKASNOSTI ALGORITMA BEZ IZMENE KODA IMPROVING EFFICIENCY ALGORITHM WITHOUT CHANGES CODE.....	161
Petar Sekulić, Milija Bajčeta, Vesna Popović-Bugarin, Slobodan Đukanović, Andrej Mihailović JEDAN PRISTUP OPTIMIZACIJI GRADSKOG SAOBRAĆAJA ONE APPROACH TO THE OPTIMIZATION OF PUBLIC TRANSPORT.....	165
Petar Sekulić, Slobodan Đukanović, Igor Đurović PRIMJENA METODE VEKTORA NOSAČA U DETEKCIJI PLAMENJAČE VINOVE LOZE DETECTION OF DOWNY MILDEW IN GRAPEVINE LEAVES USING SUPPORT VECTOR MACHINE .....	169
Elma Hot, Vesna Popović-Bugarin ANALIZA FUZZY K-MEANS KLASERIZACIJE KORISTEĆI PEDOLOŠKU BAZU PODATAKA CRNE GORE ANALYSIS OF FUZZY K-MEANS CLUSTERING METHOD USING DATABASE OF SOIL SAMPLES SAMPLED IN MONTENEGRO .....	173
Nikola Bulatović, Trifun Savić, Nikola Žarić, Ana Pešić, Aleksandar Joksimović, Marko Nikolić MONITORING OF SEA WATER PARAMETERS – “SMART BUOY” SYSTEM DEVELOPMENT MONITORING PARAMETARA MORSKE VODE – RAZVOJ SISTEMA "PAMETNA BOVA" .....	177
Trifun Savić, Milutin Radonjić PREDLOG RJEŠENJA ZA DALJINSKU KONTROLU PUTEM INTERNET APLIKACIJE ONE SOLUTION FOR REMOTE CONTROL THROUGH INTERNET APPLICATION .....	181
Stefan Vujović, Miloš Brajović, Vesna Popović-Bugarin, Nedeljko Latinović, Jelena Latinović, Milija Bajčeta WEB SERVIS ZA MONITORING VINOGRADA I PREDVIĐANJE OBOLJENJA VINOVE LOZE A WEB SERVICE FOR GRAPEVINE MONITORING AND FORECASTING A DISEASE .....	185
Miloš Brajović, Stefan Vujović, Vesna Popović-Bugarin, Slobodan Đukanović, Mirko Knežević, Ana Topalović BAZA PODATAKA ZA ANALIZU ZEMLJIŠTA I EKSPERTNI SISTEM ZA DAVANJE PREPORUKA ZA ĐUBRENJE POLJOPRIVREDNIH KULTURA SOIL ANALYSIS DATABASE AND THE EXPERT SYSTEM FOR RECOMMENDATIONS OF FERTILIZATION IN AGRICULTURE.....	189
<b>Vlatko Cingoski, Saso Gelev, Goce Stefanov, Vasilija Sarac</b> <b>INTEGRIRANE SOLARNE TERMoeLEKTRANE: SLUCAJ TE BITOLJ</b> <b>INTEGRATED SOLAR-THERMAL POWER PLANTS: TPP BITOLA CASE STUDY .....</b>	<b>193</b>
Vladan Durković, Željko Đurišić IDEJNO REŠENJE I EKONOMSKA OPRAVDANOST IZGRADNJE FOTONAPONSKE ELEKTRANE NA KROVU LABORATORIJE TEHNIČKIH FAKULTETA U PODGORICI CONCEPTUAL DESIGN AND ECONOMIC FEASIBILITY OF BUILDING ROOF TOP PHOTOVOLTAIC POWER PLANT ON THE LABORATORY OF TECHNICAL FACULTY IN PODGORICA .....	197

## INTEGRIRANE SOLARNE TERMoeLEKTRANE: SLUCAJ TE BITOLJ INTEGRATED SOLAR-THERMAL POWER PLANTS: TPP BITOLA CASE STUDY

Vlatko Cingoski, Saso Gelev, Goce Stefanov, Vasilija Sarac, *Faculty of Electrical Engineering, "Goce Delcev" University - Štip, Republic of Macedonia*

**Sadržaj:** *Potencijali za korišćenje solarne energije kao obnovljivog izvora energije, bilo njegovim pretvaranja samo u toplotu, indirektnom konverzijom u električnu energiju pomoću prethodno generisanu toplotnu energiju, ili direktno pretvaranjem solarne energije u električnu energiju fotoelektričnim efektom, su ogromni. U ovom radu pretstavljeni su rezultati Studije za razvoj integrisane solarno-termalne elektrane kao novi, dopunjski gorivni sustav postojeće termalne elektrane na uglj TE Bitolj. U predloženoj studiji, solarna energija se najpre koncentrira i pretvara u toplotnu energiju. Zatim, za korišćenje dobivene toplotne energije istraživani su dva potencijalna scenarija: (1) direktno zagrevanje radnog fluida i proizvodnju električne energije u novoj termoelektrni, i (2) kao parcijalni izvor toplotne energije za proizvodnju pare i električnu energiju u postojećim jedinicama TE Bitola koji bi mogao djelimično da zameni postojeću toplotnu energiju dobivenu sagorevanjem uglja.*

**Abstract:** *The potentials for usage of the solar energy as a renewable energy source, whether by its conversion only into heat, indirect conversion into electricity using a prior generated thermal energy, or direct conversion of solar energy into electric energy using the photoelectric effect, are enormous. This paper presents a study for the development of an integrated solar-thermal power plant (ISTPP) for repowering the existing goal-fired TPP Bitola. In the proposed plant, firstly solar energy is concentrated and converted into thermal energy. Then, two potential scenarios for utilization of the obtained thermal energy are investigated: (1) for direct heating of a working fluid and electricity production in new thermal power plant, or (2) as a partial heat energy source which could replace existing thermal energy generated by burning coal for steam and electricity generation in the existing units of the TPP Bitola.*

### 1. INTRODUCTION

The main energy topic of debate and disagreement today is providing an adequate solution to the main question: How to achieve sustainable energy development? [1] In this context, sustainable energy development means how to meet consumers' energy requirements taking into account:

- i. steady increase in energy consumption needs,
- ii. steady increase of prices of primary and secondary energy resource,
- iii. reduction of fossil fuel energy resources worldwide,
- iv. emission reduction of greenhouse gases, and
- v. protecting the environment and our planet as a whole.

Today it is mainly considered that the solution of this energy problem leads in two directions: (1) increasing energy efficiency, or generally reduce energy consumption, and (2) increasing and constantly include renewable energy sources, primarily the energy of the Sun and its derivatives such as wind energy, tidal energy and water waves in a suitable package of economic acceptable energy sources. Because the last two types of energy are strictly location limited, the wind energy and the solar energy really represent a significant energy potential which unfortunately today is either totally neglected or only modestly appears on the energy market.

In this paper a brief analysis of new and potential technology for utilization of solar energy as a natural and theoretically inexhaustible renewable energy source is

presented. The recently developed study for repowering of the TPP Bitola [2] by means of a new so-called integrated solar-thermal power plant (ISTPP) technology is based on hybrid utilization of solar power and any other mostly desirable fossil fuel, in our case coal. Firstly, harvesting of the solar energy is done by means of a concentrated solar power plant. Later, using adequate heat exchangers the harvested solar energy could be used for water heating, either directly for production of steam and generation of electricity in the whole new, however TPP with smaller installed capacity, or as a partial heat source that would be reheated burning coal (or other fossil fuels), to produce steam and to generate electricity using the existing unit of the TPP Bitola.

Evaluations of major technical and economical benefits are presented in this paper. The cost of investment is also given and compared against achieved environmental benefits and fossil fuel savings. Finally, the influence on the prices of electricity which the increased investment and O&M cost of such integrated power plant is presented, showing that this new and emerging technology deserves further investigations in the future as a potential model for the development of contemporary and more environmentally friendly upgrades of the existing fossil fueled based TPP.

### 2. SOLAR ENERGY UTILIZATION

The Sun is the main primary energy source on the Earth. As a result of the thermonuclear reactions occurring deep in its interior, huge amounts of energy is distributed racially

from the Sun's surface in all directions. It is assumed that every second the Sun emits energy with a value of about  $400 \cdot 10^{24}$  W, and that will last in the next 5 billion years. From this huge amount of energy, the Earth gets a very small portion, but still considerably large amount of energy on average of  $1.37 \text{ kW/m}^2$  annually.

Today there are few more or less known technologies for utilization of solar energy, schematically shown in Fig. 1. Generally, there are three main technologies for harnessing solar energy: (1) through its direct conversion into electricity using photovoltaic effect (PV cells), (2) as an alternative fuel to other fossil fuels for heating using solar heat collectors, and (3) the so-called solar-thermal power plants that can be found in various appearances [2].




Fig. 1: Methods for harnessing the solar energy.

Although, the oldest method for harnessing the solar energy was probably using this energy for substituting energies obtained from other energy sources, today the most promising method for harnessing solar energy on large scale is probably technology based on solar-thermal power plants. Recently, the PV cells appeared on the energy market as emerging power source, unfortunately only on limited scale. It is obvious that their role on the energy market could not be significant, mostly due to the following reasons:

- i. The photovoltaic energy converters (PV cells), provides conversion of a direct sunlight (energy) into electricity. This means that this kind of power generation practical work only in the period when there is a direct sunlight i.e. only during the day. This is an inefficient system for energy production because electricity is needed during periods when there is no sunlight, too. Therefore, special storage devices are needed for storing electricity during the daylight to be used in other periods. On the other hand, the heat storages are much simpler, cheaper and more efficient than electricity storages, thus the thermal energy stored during the day without large losses could be turned into electricity at night, making solar thermal power plants economically the most favorable way to convert solar energy into electric energy.
- ii. A solar thermal power plants operate on the principle of concentrating the solar energy to create a high temperature of the working fluid which is later used for the propulsion of the corresponding turbine

connected to an electrical generator and producing electricity. The working fluid might be liquid or gas, such as water, oil, various molten salts, air, nitrogen or helium, while as turbines usually could be used steam or gas turbines. These plants are generally quite efficient in the rate of 30% to 40% and with a capacity of 10s and up to 100s MW, which is very important in electricity generation.

Having all these in mind, a study was performed to investigate the possibility of full or partial replacement of the coal as fossil fuel in the TPP Bitola [3]. Since The Republic of Macedonia has large global solar irradiation value of about  $1.53 \text{ kW/m}^2$  annually, the general aim of the study was to perform technical and financial investigation of the potentials for the development of ISTPP as a repowering scheme of the existing TPP Bitola, as shown in Fig. 2.




Fig. 2: Scheme of the integrated solar-thermal power plant.

### 3. POTENTIALS FOR DEVELOPMENT OF ISTPP

The first step towards development of such integrated or hybrid TPP was to define the potential for solar energy harvesting and available free space in the vicinity of the TPP to be used for that purpose. Today on the solar market for the concentrated solar power (CSP) there two commercially available technologies: (1) parabolic trough (PT) technology, and (2) Liner Fresnel through (LFT) technology. Both use so-called line focusing of the solar energy in the piping system through which flows working fluid that extracts solar energy and transports it into suitable thermal reservoirs or thermal storage system. The major difference between these two systems is the shape of the solar mirrors, which in case of PT mirrors have curved parabolic shape, while in case of LFT mirrors are flat, however with appropriate spatial position to focus the solar energy into linear piping system. The other two technologies mentioned on Fig. 1, and Fig. 3, solar tower and parabolic dish were not taken into consideration because they are still not in commercial use.

Obviously, to obtain the large amount of harvested solar energy, it is necessary to have a huge amount of reflecting mirrors, and consequently, large available area for locating them. Surrounding TPP Bitola, several potential free areas were investigated, and as the most suitable the location field n° 1 was selected for several reasons, such as closeness to the existing power plant, accessibility, available space and



distance from the local pollutants, such as flying ash, coal dust and other emission particles, etc. This field has a total available area of 390,000 m<sup>2</sup> which, in accordance with the study could be enough for installation of concentrated parabolic solar panels with maximal capacity of 50 MW<sub>th</sub>.




Fig. 3: Concentrated solar power: (a) parabolic through (PT), (b) linear Fresnel trough (LFT), (c) solar tower, and (d) parabolic dish.




Fig. 4: Investigated potential location for concentrated solar fields (n° 1 to n° 4) and geological borelogs (B1 & D1).

Since the installed electric power unit at TPP Bitola has capacity of 225 MW, it is readily seen that the total thermal capacity of 50 MW<sub>th</sub> obtained by the concentrated solar field is not enough to entirely replace existing fuel. Therefore, two possibilities remains, either (1) construction of entirely new TPP with much lower installed capacity, or (2) use the generated solar energy as partial replacement for the thermal energy needed by the existing thermal power plant, currently supplied by the coal firing. The second approach seemed more viable and was accepted as preferred. However, even with this approach, several possible options for integration of the generated solar heat generated with the existing TPP had to be considered, such as:

- i. Injection in the cold reheat stream,
- ii. Boiler preheating,
- iii. HP feed water heater (FWH) by-pass, and

- iv. LP feed water heater (FWH) by-pass.

Options for remodeling of the existing power plant are summarized in Table 1. For security reasons and after detailed consultation with the producers of the boiler and turbine, the Option 2 was selected since it was easier to perform a modest remodeling of the boiler instead of huge and uncertain remodeling of the turbine.

Table 1: Considered solar heat integration options.

Integration options	Temperature of the primary fluid	Pressure of the primary fluid	Conventional equipment impacted
Option 1	340°C	30 bar	Turbine
Option 2	285°C	155 bar	Boiler
Option 3	250°C	155 bar	Turbine
Option 4	160°C	7.2 bar	Turbine

In the selected Option 2, the solar-thermal energy is used to raise the feed water temperature between the last feed water heater and the inlet of the boiler, as shown in Fig. 5. This aims at decreasing the thermal power of the boiler during the sunny hours, and avoids any modification on the operating parameters of the turbine and does not impact the boiler efficiency.




Fig. 5: Basic scheme of the boiler preheating integration option.

#### 4. EXPECTED TECHNICAL PERFORMANCES

In accordance with the measured data, the performance of the solar field is modeled and presented on Fig. 6. As expected, during the summer months when the amount of solar energy and the number of solar hours is larger, the heat production is larger and the energy substitution is also larger, as can be seen from Fig. 7. The major ISTPP performance data is presented in Table 2.




Fig. 6: Thermal performance of the solar field.




Fig. 7: Monthly net electricity production of the hybrid solar and coal power plant

Table 2: Major ISTPP performance data.

Annual average solar heat production	[GWh <sub>th,solar</sub> ]	53
Solar heat to elec. conversion eff.	[%]	48
Solar electricity produced	[GWh <sub>e,solar</sub> ]	25
Elec. produced by one coal-fired unit	[GWh <sub>elec</sub> ]	1,500
Solar elec. production / one unit	[%]	1,67
Elec. produced by TPP Bitola	[GWh <sub>elec</sub> ]	4,500
Solar elec. production ratio / TPP Bitola	[%]	0,55

## 5. EXPECTED FINANCIAL PERFORMANCES

The expected financial performances initially were analyzed for parabolic trough (PT) and linear Fresnel trough (LFT) technology, separately. It was found that the difference in the investments are marginal, since the PT technology needs less PT mirrors, less available land and has a little better efficiency than the LFT technology. However, the price of PT mirrors are little higher than that of LFT mirrors, and the O&M of the LFT mirrors is easier and cheaper. The expected investment cost and O&M of the solar field based on LFT technology are summarized in Table 3. The expected economical data and their influence on the prices if the generated electricity in the TPP Bitola, are given in Table 4.

As can be seen from Table 4, investment in solar field and construction of new hybrid power plants based on integration of solar field energy generation and conventional coal-fired TPP could be very successful approach toward substitution of fossil fuels with environmentally friendly renewable energy sources, in this case solar energy. The potentially expected negative financial effects could be observed as modest increase of 0,21, 0,07 and 0,05 €cents/kWh<sub>el</sub> on the

production price of the existing one unit, the whole TPP Bitola with three units, and the entire ELEM's energy production. In percentage to the existing regulated tariff these increase amounts for 5,2%, 1,8% and 1,3%, respectively which is financially very attractive solution in comparison either with generation price of PV solar power plants, or investment in other emerging technologies such as Carbon-capture storage power plants.

Table 3: Investment and O&M cost for LFT solar field.

Investment cost	
Intermediate heat exchanger	1,500,000 □
Solar field preparation	500,000 □
Auxiliaries	1,000,000 □
Solar field collectors	21,744,000 □
Heat pipes (solar field to TPP)	1,200,000 □
Contingencies	5,188,800 □
<b>Total:</b>	<b>31,132,800 □</b>
O&M cost/annually	
Maintenance (1% of the Investment)	311,328 □
Management fee (8,800 □/man/year)	70,400 □
Water consumption	900 □
Insurance (1% of the Investment)	311,328 □
<b>Total:</b>	<b>693,966 □</b>

Table 4: Marginal cost and tariff changes for the ISTPP.

Annual unit production	1,500,000	MWh <sub>el</sub>
Annual TPP Bitola production	4,500,000	MWh <sub>el</sub>
Annual ELEM production	6,000,000	MWh <sub>el</sub>
Solar electricity production	25,745	MWh <sub>el</sub>
portion of unit production	1.72	%
portion of whole TPP Bitola	0,57	%
Solar electricity production cost	16,49	€cents/kWh <sub>el</sub>
Added marginal cost /1 unit	0,21	€cents/kWh <sub>el</sub>
/TPP Bitola	0,07	€cents/kWh <sub>el</sub>
/total ELEM production	0,05	€cents/kWh <sub>el</sub>

## 6. CONCLUSION

In this paper a new approach for repowering of the existing, especially coal-fired TPP is presented. The concept is based on integrated utilization of the existing heat generation system of coal-fired TPP with the development of concentrated solar field for generation of additional heat utilizing solar energy as renewable energy resource. The technical and economical benefits of such a scheme are presented for the existing TPP Bitola.

## REFERENCES

- [1] UNIDO, "Sustainable Energy for All: A Global Action Agenda," *The Secretary-General's High-Level Group on Sustainable Energy for All*, April 2012.
- [2] Jasper Frenzel, "Concentrated Solar Thermal Power plants: The future of power supply in Europe," MSc. Thesis, Ritsumeikan Asia Pacific University, 2011.
- [3] AD ELEM, ARTELUM, and CARBONIUM, "Concentrated Solar Power Plant: Design of the Hybrid SCP Plant," Feasibility Study, Skopje, 2012.